NOTE:

The (3) number is not intended to identify a specific circuit breaker or location inside the load center but to identify the circuits only.
Circuits shall be balanced between phases as near as possible in accordance with N.E.C. Section 220.

WIRING SIZES

15 amp circuits #14 copper*	45 amp circuits #8 copper
20 amp circuits #12 copper*	50 amp circuits #6 copper
25 amp circuits #10 copper*	60 amp circuits #6 copper
30 amp circuits #10 copper	70 amp circuits #4 copper
40 amp circuits #8 copper or **	100 amp circuits #3 copper

* 75°C min. temperature rating with equipment terminations listed and identified for 75°C. Type THW or THWN.

** Type NM cable three #7 values tube 310-15

PANEL

ELECTRICAL LOAD CALCULATIONS

(3) NO.	AMPS/ POLES	DESCRIPTION	CONNECTED LOAD	DEMAND LOAD FACTOR	DEMAND LOAD	TOTAL LOAD
1	15/1	LIGHTS	840 VA @ 120	100%	1.25	1050
2	15/1	RECEPT.	2160 VA		1.00	2160
3	20/1	BASEBOARD HEATER	2700 VA		1.25	3375
4	15/1	AC	960		1.00	960